NEUWALL PARTITION WALL
NO.8 ZHONGYI INDUSTRY PARK,PANYU DISTRICT,
GUANGZHOU CITY,CHINA

The following sample(s) was / were submitted and identified on behalf of the client as:

Sample Description	:	100-125 HIGH STEEL SLIDING TRACK
Manufacturer	:	NEUWALL PARTITION WALL.
Country of Origin	:	CHINA
Sample Receiving Date	:	Apr.18, 2018
Test Performing Date	:	Apr.18, 2018 to May 31, 2018

Test Result Summary

Test(s) Requested	Result(s)
Horizontal slide (loading) and durability test of sliding partition door track (Durability of sliding doors and horizontal roll fronts with reference of BS 4875-7:2006 (Level 3))	PASS

Summary:

1. For further details, please refer to the following page(s).

Signed for and on behalf of
Shunde Branch
SGS-CSTC Co., Ltd.

Hary Nie
Approved signatory



SGS-CSTC Standards Technical Services Co., Ltd. Shunde Branch Hardware

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307 1443, or email: CN.Doccheck@sgs.com

1F,1st Building,European Industrial Park,No.1 Shunhe South Road,Wusha Section,Daliang Town,Shunde,Foshan,Guangdong,China 528333 t (86-757)22805888 f (86-757)22805858 www.sgsgroup.com.cn
中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编：528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

TESTS AND RESULTS

Test Conducted:

Horizontal slide (loading) and durability test of sliding partition door track (Durability of sliding doors and horizontal roll fronts with reference of BS 4875-7:2006 (Level 3)).

No. of Sample:

1 piece. For more sample information and pictures, please refer to the following page.

Test and Requirements	Test Results
Horizontal slide (loading) and durability test of sliding partition door track Assemble the track and one set of caster on the test frame provided by applicant. Load the track and caster with load of 500 kg, and connect the test frame to a cycling machine which can lead the frame move back and forth. A cycle consists of push the frame to 500 mm forward and pull back to the original position (total 1,000 mm). The number of test cycle is 40,000 and the frequency is 6 to 15 times per minute. After the test, the track shall keep its function.	PASS

Remark:

1. The test method was referenced to clause 7.2.3 of ISO 7170:2005;
2. The total load 500 kg and cyclic number 40,000 were specified by client;
3. Lubricate the castes in each 10,000 cycles is specified by applicant;
4. For the sample information and pictures, please refer to the following page;

SGS-CSTC Standards Technical Services Co., Ltd. Shunde Branch Hardware

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307 1443, or email: CN.Doccheck@sgs.com

1F,1st Building,European Industrial Park,No.1 Shunhe South Road,Wusha Section,Dailang Town,Shunde,Foshan,Guangdong,China 528333 t (86-757)22805888 f (86-757)22805858 www.sgsgroup.com.cn
中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编：528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Sample as Received



View 1

End of Report

SGS-CSTC Standards Technical Services Co., Ltd. Shunde Branch Hardlines

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307 1443, or email: CN.Doccheck@sgs.com

1/F,1st Building,European Industrial Park,No.1 Shunhe South Road,Wusha Section,Dailang Town,Shunde,Foshan,Guangdong,China 528333 t (86-757)22805888 f (86-757)22805858 www.sgsgroup.com.cn

中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编：528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)